



Valvoindustria Ing. Rizzio S.p.a.

Via Circonvallazione,10 - 13018 Valduggia - Italy

Tel. +39 0163 47891 - Fax +39 0163 47895 - E-mail: info@vironline.com

Cap. Soc. €. 5.000.000,00 int. vers. – R.E.A. di Vercelli n. 102566 – Pos. Mecc. VC 000506

Reg. Impr. VC / Cod. Fisc. /P. IVA 00166310029



Declaration n. 02.07.EN

Valduggia, 23/01/2020

EU DECLARATION OF CONFORMITY
according to ISO/IEC 17050-1

VIR Valvoindustria Ing. Rizzio S.p.A.

a company with Quality Management System in compliance with the standard UNI EN ISO 9001:2015

DECLARES

under its sole responsibility that the design and the conformity assessment for the

BRASS AND BRONZE BALANCING VALVES

are in compliance with

Directive 2014/68/EU (PED)

Pressure equipments are classified depending on
the contained fluids, maximum allowable pressure and nominal size.

For pressure equipments classified in category I the conformity assessment
procedure Module A and the CE marking are applied.

Pressure equipments according to Art. 4.3 are free of CE marking (SEP).

Refer to the international catalogue and specific data sheet for information about
PED category, fluids suitability and correspondent maximum allowable pressure.

President
ing. Savino Rizzio



Valvoindustria Ing. Rizzio S.p.a.

Via Circonvallazione,10 - 13018 Valduggia - Italy

Tel. +39 0163 47891 - Fax +39 0163 47895 - E-mail: info@vironline.com

Cap. Soc. €. 5.000.000,00 int. vers. – R.E.A. di Vercelli n. 102566 – Pos. Mecc. VC 000506

Reg. Impr. VC / Cod. Fisc. /P. IVA 00166310029



Declaration n. 02.01.01.EN

Valduggia, 26/01/2021

EU DECLARATION OF CONFORMITY
according to ISO/IEC 17050-1

VIR Valvoindustria Ing. Rizzio S.p.A.

a company with Quality Management System in compliance with the standard UNI EN ISO 9001:2015

DECLARES

under its sole responsibility that the design and the conformity assessment for the

Fig. 9555P

Variable Orifice Cast Iron Double Regulating Valve

nominal size for piping (DN) 40 ÷ 400

maximum allowable pressure (PS) 16bar

suitable for liquid water between -10°C and +110°C

(Ethylene glycol and propylene glycol mixtures up to 50% may be used)

are in compliance with

Directive 2014/68/EU (PED)

free of CE marking (SEP) according to Art. 4.3 for DN ≤ 300

classified in Cat. I and CE marked for DN ≥ 350

not suitable for liquids group 1, gases group 1 and 2

President
ing. Savino Rizzio



Valvoindustria Ing. Rizzio S.p.a.

Via Circonvallazione,10 - 13018 Valduggia - Italy

Tel. +39 0163 47891 - Fax +39 0163 47895 - E-mail: info@vironline.com

Cap. Soc. €. 5.000.000,00 int. vers. – R.E.A. di Vercelli n. 102566 – Pos. Mecc. VC 000506

Reg. Impr. VC / Cod. Fisc. /P. IVA 00166310029



Declaration n. 02.05.EN

Valduggia, 23/01/2020

EU DECLARATION OF CONFORMITY
according to ISO/IEC 17050-1

VIR Valvoindustria Ing. Rizzio S.p.A.

a company with Quality Management System in compliance with the standard UNI EN ISO 9001:2015

DECLARES

under its sole responsibility that the design and the conformity assessment for the

BRASS AND BRONZE BALL VALVES

are in compliance with

Directive 2014/68/EU (PED)

Pressure equipments are classified depending on
the contained fluids, maximum allowable pressure and nominal size.

For pressure equipments classified in category I the conformity assessment
procedure Module A and the CE marking are applied.

Pressure equipments according to Art. 4.3 are free of CE marking (SEP).

Refer to the international catalogue and specific data sheet for information about
PED category, fluids suitability and correspondent maximum allowable pressure.

President
ing. Savino Rizzio



Valvoindustria Ing. Rizzio S.p.a.

Via Circonvallazione,10 - 13018 Valduggia - Italy
Tel. +39 0163 47891 - Fax +39 0163 47895 - E-mail: info@vironline.com
Cap. Soc. €. 5.000.000,00 int. vers. – R.E.A. di Vercelli n. 102566 – Pos. Mecc. VC 000506
Reg. Impr. VC / Cod. Fisc. /P. IVA 00166310029



Declaration n. 02.06.EN

Valduggia, 23/01/2020

EU DECLARATION OF CONFORMITY
according to ISO/IEC 17050-1

VIR Valvoindustria Ing. Rizzio S.p.A.

a company with Quality Management System in compliance with the standard UNI EN ISO 9001:2015

DECLARES

under its sole responsibility that the design and the conformity assessment for the

BRASS AND BRONZE GATE VALVES

are in compliance with

Directive 2014/68/EU (PED)

Pressure equipments are classified depending on
the contained fluids, maximum allowable pressure and nominal size.

For pressure equipments classified in category I the conformity assessment
procedure Module A and the CE marking are applied.

Pressure equipments according to Art. 4.3 are free of CE marking (SEP).

Refer to the international catalogue and specific data sheet for information about
PED category, fluids suitability and correspondent maximum allowable pressure.

President
ing. Savino Rizzio